



EVPU®

NOTIFIED BODY No. 1293

CERTIFICATE OF CONSTANCY OF PERFORMANCE

No. 1293 – CPR – 0906 Rev.1

In compliance with *Regulation (EU) No 305/2011 of the European Parliament and of the Council of March 9th, 2011* (the Construction products Regulation or CPR), this certificate applies to the construction product

Sounder base TFBASE-SIREN 

For specifications see Annex to this certificate

placed on the market under the name or trade mark of

**TECNOALARM s.r.l.,
Via Cirie 38, 10099 San Mauro - Torino, Italy**

and produced in the manufacturing plant

**TECNOALARM s.r.l.,
Strada del Cascinotto 139/54, 10154 Torino, Italy**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance described in Annex ZA of the standard(s)

EN 54-3: 2001, EN 54-3:2001/A1:2002, EN 54-3:2001/A2:2006

under system 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the

constancy of performance of the construction product.

This certificate was first issued on May 6th, 2024 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, unless suspended or withdrawn by the notified product certification body.



Nová Dubnica, February 16th, 2026


Robert Janiga
Head of NB No. 1293

055745

EVPU a.s., NO 1293, AO SK08, Trenčianska 19, SK 018 51 Nová Dubnica, Slovak Republic, www.evpu.sk

Identification number: 31 562 507
Page 1 / 2 F COCV 7.7.12 Rev.1

Annex to Certificate No. 1293 - CPR – 0906 Rev.1 from February 16th, 2026

General Information:

The Sounder base TFBASE-SIREN is a universal base with acoustic signaling device for Tecnofire detectors.

The TFBASE-SIREN meets EN 54-3 and IP22 requirements only when used in conjunction with a mounted detector.

Technical parameters:

Rated voltage:	24VDC
Power supply:	over loop
Operating voltage:	21V... 30VDC
Sound type:	8 settings
Volume:	2 settings
Protection class:	IP22 (with detector mounted)
Dimensions (Ø x H)	108 x 52mm
Casing:	PC ABS V0

Product parameters:

Essential characteristics	Harmonised technical specifications	Performance
	EN 54-3:2001 EN 54-3:2001/A1:2002 EN 54-3:2001/A2:2006	
Performance under fire conditions	cl. 4.2, 4.3, 5.2, 5.3, C.3.1=N/A, C.3.2=N/A, C.5.1 to C.5.3=N/A	Pass
Operational reliability	cl. 4.4, 4.5, 4.6, 5.4, C.4=N/A	Pass
Durability of operational reliability: temperature resistance	cl. 5.5, 5.6=N/A, 5.7, 5.8, 5.9	Pass
Durability of operational reliability: humidity resistance	cl. 5.8, 5.9, 5.10=N/A	Pass
Durability of operational reliability: corrosion resistance	cl. 5.11	Pass
Durability of operational reliability: shock and vibration resistance	cl. 5.12 to 5.15	Pass
Durability of operational reliability: electrical stability	cl. 5.16	Pass
Durability of operational reliability: resistance to ingress	cl. 5.17	Pass


The Sounder Base TFBASE-SIREN was also tested in accordance with EN 54-3: 2014 + A1: 2019.

History of certification:

No.	Certificate No.	Description	Date of issue
1.	1293-CPR-0906	Original CPR certificate issued	May 6 th , 2024
2.	1293-CPR-0906 Rev.1	Additional tests according to the standard EN 54-3: 2014 + A1: 2019	February 16 th , 2026



Nová Dubnica, February 16th, 2026


 Róbert Janiga
 Head of NB No. 1293