

## **Tecnofire** Strada del Cascinotto 139/54 10156 TORINO (TO) ITALY



## PERFORMANCE DECLARATION

(Regulation UE nr.305/2011 – annexe III) Nr. 011\_TFM10

1	Unique identification code of the product-type:			TFM10	TFM10	
2	Type, batch or serial number or any other element allowing identification of the construction product as required pursuant to Article 11(4):			See label (serial n	See label (serial number)	
3	Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:			Input/output device	Input/output devices 1 in 0 out	
4	Name, registered trade name or registered trade mark and contact address of the manufacturer as required pursuant to Article 11(5):				Tecnoalarm s.r.l Via Ciriè 38 10099 SAN MAURO (TO) - ITALY	
(5)	Where applicable, name and contact address of the authorized representative whose mandate covers the tasks specified in Article 12(2):			N.A.	N.A.	
6	System or systems of assessment and verificat construction product as set out in Annex V:	cion of constancy of	f performance of the	System 1	System 1	
7	In case of the declaration of performance concerning a construction product covered by a harmonized standard:  EVPU - the notified product certification body - shall issue the certificate of constancy of performance of the product on the basis of:  (i) determination of the product-type on the basis of type testing (including sampling), type calculation, tabulated values or descriptive documentation of the product;  (ii) initial inspection of the manufacturing plant and of factory production control;  (iii) continuous surveillance, assessment and evaluation of factory production control;					
8	In case of the declaration of performance concerning a construction product for which a European Technical Assessment has been issued:					
9	DECLARED PERFORMANCE					
	Essential characteristics	Declared Performance	EN54-18:2005/AC:2007	EN54-17:2005		
	Response delay (response time)	Pass	Art. 5.2			
	Performance under fire conditions	Pass	Art. 5.1.4	Art. 5.2		
	Operational reliability	Pass	Art. 5.1.4	Art. 4		
	Durability of operational reliability; temperature resistance	Pass	Art. 5.3-5.4	Art. 5.4-5.5		
	Durability of operational reliability; vibration resistance	Pass	Art. 5.8 to 5.11	Art. 5.9 to 5.12		
	Durability of operational reliability; humidity resistance	Pass	Art. 5.5-5.6	Art. 5.6-5.7		
		ave a	Art. 5.7	Art. 5.8		
	Durability of operational reliability; corrosion resistance	Pass		1		

Signed for and on behalf of the manufacturer by:

Mr. Giovanni NEGRO - Management

San Mauro Torinese, lì June, 03, 2015

Signature