



DECLARATION OF CONFORMITY

Tecnoalarm S.r.l. declare under their sole responsibility that the product which this declaration relates to:

Name: **TFCP-IP55**
Description: Manual call point

is in compliance with all relevant essential requirements and other relevant provisions of the directives:

LVD 2014/35/EU Low Voltage Directive
EMC 2014/30/EU Electromagnetic Compatibility

and the regulation:

CPR 305/2011 Construction Products Regulation (CPR)

Compliance with these directives implies conformity to the following European norms:

EN 50130-4:2011 + A1:2014	Immunity requirements for components of fire, intruder, hold up, CCTV, access control and social alarm systems – Intrusion and hold-up systems – Part 4: Electromagnetic compatibility
EN 55032:2015 + A11:2020	Electromagnetic compatibility of multimedia equipment - Emission Requirements
EN 54-11:2001 + A1:2005	Fire detection and fire alarm systems – Part 11: Manual call points
EN 54-17:2005	Fire detection and fire alarm systems – Part 17: Short-circuit isolators

San Mauro Torinese, 27 January 2022

Negro Giovanni
Management

Tecnoalarm S.r.l.

Via Ciriè, 38 - 10099 San Mauro T.se - Torino (Italy) - Unità produttiva: Strada del Cascinotto, 139/54 - 10156 Torino
Tel. +39 011 22 35 410 - Fax +39 011 27 35 590 - info@tecnofireddetection.com - www.tecnofireddetection.com

R.I. e C. F/P. Iva 01792190017 - REA TO 518027 - CODICE UNIVOCO M5UXCR1 - Comm. Estero: posiz. TO 001239 - Cap. Soc. i.v.: Euro 500.000,00